

**Clarification to Prebid Queries for:
Procurement of 11KV XLPE Cable and Control Cable
Package no. Jammu -Urban/EE/05**

S.No.	Reference to Clause	Quarries	Reply
1	Vol-1, Sec-VI	The technical specifications as per clause 3 calls for FRLS cables under scope where as the GTP mentions PVC type ST2 under point no.8.	Outer sheath to be provided with FRLS PVC conforming to relevant IS.
2	Vol-1, Sec-VI	Under point no.6 (a) of GTP, your requirement is of PVC tape where as point 6 (b) calls for extruded. It can either be PVC tape or extruded please clarify.	Inner sheath to be provided with extruded PVC as per IS 7098/Part-II/1985 and amended up to date
3	Vol-1, Sec-VI	The requirement of SC 13.12KV/18.35 KA for 3 sec. This require copper wire screen in place of Cu tape as mentioned in 5 (b) of GTP.	Copper wire screen shall be applied with 100% coverage instead of copper tape because of the requirement of short circuit current 18.35 KA for 3 seconds

SE (Elect.)

AEE

TL(DSC-1)